Certificate of compliance with the order 2.1 according to EN 10 204

HELUKABEL® GmbH
Dieselstraße 8 - 12
71282 Hemmingen/Stuttgart
Germany
Phone (0 71 50) 92 09-0
Fax (0 71 50) 8 17 86
www.helukabel.de

Date: 04.10.2016
limited in time: 31.10.2017

J-Y(St)Y Lg

We confirm that above mentioned telephone installation cable are produced according to DIN VDE 0815 and tested according to DIN VDE 0473/0481.

- **Temperature range**
  during operation - 5°C to + 50°C
  fixed installation - 30°C to + 70°C
- **Operating peak voltage** Conductor ∅ 0,6 mm and 0,8 mm 300V
- **Conductor ∅ 0,8 mm** short time operation (6 s/min) up to 600 V permitted (not for purposes of high current and power installation)

Test

- PVC self-extinguishing and flame retardant according to DIN VDE 0482-332-1-2, DIN EN 60332-1-2, IEC 60332-1-2.

The materials used in manufacture are cadmium-free and contain no silicone and free from substances harmful to the wetting properties of lacquers.

CE = Product conforms with Low-Voltage Directive 2014/35/EU.

HELUKABEL® GmbH

HELUKABEL